



M1659200D.1

ITEM NUMBER: 1659200, 1659201, 1659202

SERIAL NUMBER: _____

Owner's Manual

Instructions for Installation/Set-up, Operation, Servicing, & Storage

Portable Outdoor Use-Only, Direct-Driven Replacement Generator

1659200 - 3,000 Watt Continuous (3,500 Watt Surge) Capacity

1659201 - 4,000 Watt Continuous (4,500 Watt Surge) Capacity

1659202 - 6,000 Watt Continuous (6,500 Watt Surge) Capacity

WARNING

READ and UNDERSTAND this manual completely before using the generator! Failure to properly set up, operate, and maintain this generator could result in *serious injury or death* from *carbon monoxide poisoning, electric shock, entanglement, fire, or burns*. In addition, an improperly secured generator *can lift or flip and cause severe injury*. In particular, be aware of the following hazards:

CO Poisoning

The running engine gives off carbon monoxide, a poisonous gas that can kill you. You CANNOT smell it, see it, or taste it.

- ONLY run generator-engine assembly OUTDOORS and AWAY from building air intakes. NEVER run inside any enclosed or semi-enclosed spaces, including homes, basements, garages, sheds, and boxes. These spaces can trap poisonous gases, EVEN if you run a fan or open windows.
- Install carbon monoxide alarms inside nearby structures/buildings (battery-operated, or plug-in with battery backup).

Electric shock / Electrocution

- High voltage electricity from generator can kill. DO NOT operate in wet locations. Be sure generator is properly grounded. Use only UL-listed, outdoor-rated grounded GFCI-equipped extension cords of proper size.
- NEVER plug the generator directly into a wall outlet. ANY connection to a building's electrical system MUST ISOLATE THE GENERATOR FROM UTILITY POWER via a UL-approved transfer switch installed by a licensed electrician. Otherwise, back feed from the generator into the power grid could kill utility workers.

Fire

- DO NOT overload generator (per rated capacity), and OPERATE ONLY in an area with adequate cooling ventilation so generator does not overheat and possibly cause fire. Keep all objects at least 7' from generator vent openings. Refer to engine owner's manual for minimum safe clearance distance between hot engine exhaust and nearby combustible materials/structures.
- ALWAYS keep a fire extinguisher rated "ABC" nearby.

Entanglement / Moving Object Impact

- Never operate the generator without proper guarding of the power transmission assembly, including all rotating shafts, pulleys, belts, and couplings. Clothing or hair can become rapidly entangled in unguarded rotating parts, resulting in *serious injury or death*.
- Failure to properly mount and secure the generator may cause the unit to lift or flip during use, which could result in severe injury to the operator or bystanders, or cause damage to surrounding objects.

Also see "Summary of Important Safety Information" in this manual.

STOP!

CHOOSE THE RIGHT GENERATOR FOR YOUR NEEDS. See the "Power load Planning & Management" section of this manual to determine your power load requirements and then compare to the generator's rated capacity.

INSPECT COMPONENTS: Closely inspect to make sure no components are missing or damaged. See the "Unpacking & Delivery Inspection" section for instructions on whom to contact to report missing or damaged parts.

ENGINE and MOUNTING REQUIRED. You will need to supply an engine to power this generator. The generator and engine must be mounted to each other. See the "Specifications", "About Your Generator", and "Installation/Initial Set-Up" sections of this manual for more information on these requirements.

ARRANGE FOR PROFESSIONAL INSTALLATION of a transfer switch if you will be connecting the generator to your building's electrical system. See the "Installation/Initial Set-Up" section for more information about this requirement.

Any Questions, Comments, Problems, or Parts Orders

Call NorthStar Product Support 1-800-270-0810

Hazard Signal Word Definitions






	<p>This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages that follow this symbol to avoid possible injury or death.</p>
	<p>DANGER (red) indicates an imminently hazardous situation which, if not avoided, will result in death or serious injury.</p>
	<p>WARNING (orange) indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury.</p>
	<p>CAUTION (yellow) indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury.</p>
	<p>CAUTION (yellow) used without the safety alert symbol indicates a potentially hazardous situation which, if not avoided, may result in property damage.</p>

fig01453

Table of Contents

Hazard Signal Word Definitions	2
About Your Generator	4
Specifications	6
Safety Label Locations.....	7
Machine Component Identification	8
Power Load Planning & Management	10
Installation / Initial Set-Up:	
1. Unpacking & Delivery Inspection.....	12
2. Planning the Power Load.....	12
3. Set-up as a PORTABLE or BUILDING BACK-UP Power Source	13
4. Selecting a Suitable Site	15
5. Mounting & Connecting Generator and Engine.....	17
6. Connecting Generator Wire Harness to Existing Wiring	21
7. Grounding the Generator	22
Operation:	
1. General Safety Rules for Operation	23
2. Preparing for Operation (Pre-start checklist)	25
3. Starting the Generator.....	27
4. Connecting Loads	28
5. Stopping.....	29
6. Storage & Exercise	30
Maintenance & Repair.....	32
Troubleshooting.....	34
Summary of Important Safety Information	35
Fastener Identification	39
Generator Exploded View and Component Lists.....	41
Warranty	44

About Your Generator

Thank you for purchasing your NorthStar direct-driven generator!

About Your Generator

This direct-driven, portable generator is designed to provide up to:

	Continuous Watts	Surge Watts	Required Engine Horsepower
1659200	3000	3500	6 hp
1659201	4000	4500	9 hp
1659202	6000	6500	13 hp

Powered by an external engine, this generator can supply power:

1. As a portable power source. You can plug appliances directly into the generator's electrical outlets.
2. As a back up, standby power source for a building. A licensed electrician can connect the generator to your building's electrical system via the installation of an **UL-approved transfer switch**. (See the "Installation & Initial Set-up" section of this manual to learn more about specific requirements and precautions relating to wiring the generator to your building's electrical system.)

You must select a generator adequately sized for your power needs. You need to determine the power needs of all the appliances/tools you wish to power at the same time and choose a generator rated to provide at least that power level. See the "Power Load Planning & Management" section of this manual to determine your specific power load requirements and then compare them to this generator's rated capacity. You must not overload the generator. Overloading will cause damage to the generator and attached electrical devices, and may also result in fire.

This generator and the engine must be mounted together. More detailed information about mounting can be found in the "Installation / Initial Set-Up" section of this manual.

Be sure to read about site selection and grounding requirements for running this generator. More detailed information can be found in the "Installation & Initial Set-up, Steps 5 & 6" of this manual.

⚠ CAUTION: This generator is too heavy for one person to lift without assistance.

Optional accessories available from NorthStar include UL-approved transfer switches and extension cords. **Contact NorthStar Product Support at 1-800-270-0810 with questions about optional accessories or to order.**

Read this Manual

WARNING

Improper use or maintenance of the generator can result in *serious injury or death* from *carbon monoxide poisoning, electric shock, entanglement, fire, or burns*. In addition, an improperly secured generator *can lift or flip and cause severe injury*.

Read this manual completely before using the generator and follow all instructions and safety rules.

About Your Generator (cont'd)

You must follow all instructions and safety precautions presented throughout this manual. A summary of important safety information can be found at the end of the manual. Keep this manual for reference and review.

Proper preparation, operation, and maintenance will result in operator safety as well as best performance and long life of the generator. Failure to follow the instructions in this manual for proper mounting, set-up, operation, and maintenance of the generator will void the manufacturer's warranty.

Before using, the user shall determine the suitability of this product for its intended use and assumes liability therein. The purchaser and/or user shall assume liability for any modification and/or alterations of this equipment from original design and manufacture, or for any non-standard application, or for use as a subcomponent in another piece of equipment.

NorthStar is constantly improving its products. The specifications outlined herein are subject to change without prior notice or obligation.

Contact NorthStar Product Support at 1-800-270-0810 for any questions about the appropriate use of this generator.

Warranty Registration

Please fill out and submit the warranty registration section at the end of this manual so that you have information for future product literature or replacement parts you may need.

ATTENTION:
All Rental Companies and Private Owners who loan this equipment to others!

All persons to whom you rent/loan this generator must have access to and read this manual. Keep this owner's manual with the generator at all times and advise all persons who will operate the machine to read it. You must also provide personal instruction on how to safely operate the generator and remain available to answer any questions a renter/borrower might have.

Specifications


<i>SPECIFICATIONS</i>			
Item Number	1659200	1659201	1659202
Maximum Output	3500 Watts (W)	4500 Watts (W)	6500 Watts (W)
Continuous Output	3000 Watts (W)	4000 Watts (W)	6000 Watts (W)
Voltage	120 / 240 Volt (V)	120 / 240 Volt (V)	120 / 240 Volt (V)
Phase	Single phase (4-wire)	Single phase (4-wire)	Single phase (4-wire)
Frequency	58.0 – 63.0 Hertz (Hz)	58.0 – 63.0 Hertz (Hz)	58.0 – 63.0 Hertz (Hz)
Power Factor	1.0 p.f.	1.0 p.f.	1.0 p.f.
Engine HP (minimum)	6 hp	9 hp	13 hp
Engine Speed	3540-3720 RPM	3540-3720 RPM	3540-3720 RPM
Torque	9 ft-lbs	14 ft-lbs	19 ft-lbs
Engine Drive Shaft	2¼” taper per foot length of engine shaft	2 ¼” taper per foot length of engine shaft	2 ¼” taper per foot length of engine shaft
Dimensions			
Length	11”	12.5”	12.75”
Width	7.125”	7.5”	9.4”
Height	7”	7.2”	9.75”
Gross Weight	29.5 lb. (13.4 kg)	39 lb. (17.7 kg)	60.4 lb. (27.4 kg)

Safety Label Locations


DANGER

Using a generator indoors CAN KILL YOU IN MINUTES.

Generator exhaust contains carbon monoxide. This is a poison you cannot see or smell.




NEVER use inside a home or garage. EVEN IF doors and windows are open.



Only use OUTSIDE and far away from windows, doors, and vents.

779407



780342

WARNING

HIGH VOLTAGE from generator can shock or kill.



- ◆ NEVER connect generator directly into a wall outlet.
- ◆ ANY connection to a building's electrical system MUST ISOLATE GENERATOR FROM UTILITY POWER via a transfer switch.
- ◆ Be sure generator is properly grounded.
- ◆ Use only outdoor-rated grounded GFCI extension cords of proper size.
- ◆ DO NOT operate in wet locations.

Clothing or hair can become rapidly ENTANGLED in unguarded rotating parts, resulting in serious injury or death.



- ◆ ONLY operate with proper guarding of power transmission system, including all rotating shafts, pulleys, belts and couplings.

FIRE can result from:

- Overloading the generator
- Lack of cooling ventilation
- Contact with hot engine exhaust



- ◆ DO NOT overload generator
- ◆ OPERATE ONLY with adequate cooling ventilation. Keep all objects at least 7 feet from generator vent openings.
- ◆ Keep engine exhaust a safe distance away from all combustible objects.
- ◆ ALWAYS keep a fire extinguisher nearby.

Generator may LIFT or FLIP during use if improperly mounted.



Generator and engine must be properly mounted to a common base.

Read Owner's Manual completely before using.

NTE®


Always make sure safety labels are in place and in good condition. If a safety label is missing or not legible, order new labels or unsafe operation could result.

To order replacement safety labels, call NorthStar Product Support at **1-800-270-0810**.


On-Product Warning Labels

Part numbers	Description
779407	CPSC Warning
780342	General Warning

Machine Component Identification



Ref	Description	Ref	Description
1	Drive End Bracket	5	Fan Vents
2	Non-Drive End Bracket	6	Fan
3	End Cover	7	Input Shaft
4	Grounding screw slot	8	Engine Adapter Plate



Machine Component Identification (cont'd)

REFERENCE GUIDE

Reference 1 – Drive End Bracket	Connects to the Engine Adapter Plate
Reference 2 – Non-Drive End Bracket	Bracket requires support underneath to keep engine and generator level
Reference 3 – End Cover	Protective end cover shields operator from moving parts
Reference 4 – Grounding Screw	Ground the generator via the ground screw, to a copper pipe or rod that is driven into moist soil.
Reference 5 – Fan Vents	Never block the vent slots or insert objects through the slots (vents allow for cooling air to pass through generator)
Reference 6 – Fan	Fan pulls air through the generator
Reference 7 – Input Shaft	Engine input shaft must fit snugly into tapered hole
Reference 8 –Engine Adapter Plate	Connect plate to the engine and drive end bracket Engine adapter plate must be installed flush with engine or damage will occur to both engine and generator.

Power Load Planning & Management

WARNING

NEVER exceed the rated wattage capacity of your generator.

OVERLOADING may cause SERIOUS DAMAGE to the generator and attached electrical devices, and may result in fire.

Your generator **MUST BE SIZED PROPERLY** to provide both the running and starting (surge) wattage of the devices you will be powering. Before using your generator, determine the running and starting wattage requirements of all the electrical devices you will be powering simultaneously. The sum of the running and starting wattages of the devices being powered must not exceed the continuous output rating of your generator. (The continuous output rating of your generator is listed in the “Specifications” section of this manual.) Note that:

- Devices without electric motors such as light bulbs, radios, and televisions have the same running and starting wattage.
- Devices with electric motors such as refrigerators, compressors, and hand tools typically require a starting wattage that is 3 to 5 times greater than the running wattage.

The running and starting wattage requirements are often listed on a device’s nameplate. If wattage is not given on the device’s nameplate, the wattage may be calculated by multiplying the nameplate voltage by nameplate amperage, Watts = Volts X Amps.

Example conversion to watts:

$$120 \text{ Volts} \times 5 \text{ Amps} = 600 \text{ Watts}$$

If only the running voltage is given on the nameplate for a device with an electric motor, the starting wattage can be approximated to be three to five times the running wattage.

Estimates for the running wattage requirements for common devices are listed in **Table 4** below. Guidance for starting wattages is provided in the table’s footnotes.

Table 4

Device	Running Watts	Device	Running Watts
Air conditioner (12,000 BTU)	1700 (a,b)	Jet pump	800 (a)
Battery charger (20 Amp)	500	Lawn mower	1200
Belt sander (3")	1000	Light bulb (100 Watt)	100
Chain saw	1200	Microwave oven	700
Circular saw (6½")	2000 (a,b)	Milk cooler	1100 (a)
Coffee maker	1800 (a,b)	Oil burner on furnace	300
Compressor (1 HP)	1400 (a,b)	Oil-fired space heater (140,000 Btu)	400
Compressor (¾ HP)	1800 (a)	Oil-fired space heater (85,000 Btu)	225
Compressor (½ HP)	1400 (a)	Oil-fired space heater (30,000 Btu)	150
Curling iron	700	Oven	4500
Dishwasher	1200	Paint sprayer, Airless (1/3 HP)	600 (a)
Edge trimmer	500	Paint sprayer, Airless (handheld)	150
Electric nail gun	1200	Radio	200
Electric range (1 element)	1500	Refrigerator	600 (b)
Electric skillet	1250	Slow cooker	200

Power Load Planning & Management (cont'd)

Device	Running Watts	Device	Running Watts
Furnace fan (1/3 HP)	1200 (a)	Submersible pump (1-1/2 HP)	2800 (a)
Freezer	800 (b)	Submersible pump (1 HP)	2000 (a)
Hair dryer	1200	Submersible pump (1/2 HP)	1500 (a)
Hand drill (1")	1100	Sump pump	600 (a)
Hand drill (1/2")	875	Table saw	2000 (a)
Hand drill (3/8")	500	Television	500
Hand drill (1/4")	250	Toaster	1000
Hedge trimmer	450	Vacuum cleaner	250
Home computer	150	VCR	70
Impact wrench	500	Water Heater	3000
		Weed trimmer	500

(a) Hard-starting motors require 3-5 times the rated running watts

(b) For extremely hard to start loads such as air conditioners and air compressors, consult the equipment dealer to determine maximum wattage

To calculate the running and starting wattage requirements for the devices you will be powering, follow these steps:

1. Make a list of all electrical devices you will be powering at the same time with the generator.
2. List the greater of the running or starting wattage next to each device as obtained from the devices' nameplate or **Table 4**. If only the running wattage for a device with an electric motor is known, the starting wattage can be estimated to be at least 3 times the running wattage.
3. Add the wattages for all devices on your list. This total must be lower than the continuous output rating of your generator.

Example:

Device to be Powered	Greater of Starting/Running Wattage
Light Bulb	75 W
Refrigerator – 18 Cu. Ft.	1600 W
Microwave	700 W
Window AC	1800 W
Sump pump (1/3 hp)	2100 W
Total	6275W

In this example, the generator must have a continuous output of at least 6275 W in order to power all of the devices simultaneously.

STAGGERING LOADS

You can increase the number of devices your generator can power by staggering the load on the generator. For example, you could alternately power your refrigerator and air conditioner for limited periods of time -- powering only one of the devices at a time and never powering both at the same time.

Installation / Initial Set-Up

There are a number of important steps required to set up your generator for initial use. These steps are:

Steps for Installation / Initial Set-Up

- 1. Unpacking & delivery inspection.**
- 2. Planning the power load to stay within the generator's rated capacity.**
- 3. Setting up for the type of power generation you need:**
 - a. portable power source, or**
 - b. connected to a building as a back-up power source.**
- 4. Selecting a site for using the generator.**
- 5. Mounting & connecting generator to engine.**
- 6. Connecting Generator Wire Harness to Existing Wiring**
- 7. Grounding**

Each of these steps is discussed in detail below:

1. Unpacking & Delivery Inspection

1. You should inspect the generator immediately after you receive delivery.

See the "Machine Component Identification" section of this manual for a diagram of the generator and its components.

- If you have missing or damaged components, contact Product Support at 1-800-270-0810.

2. Planning the Power Load

Plan your power load so that you do not exceed the generator's rated capacity.

See the "Power Load Planning & Management" section of this manual to review how to plan and manage power loads for the generator.

Installation / Initial Set-Up

3. Set-up either as a BUILDING BACK-UP or PORTABLE Power Source

Each model generator is designed to provide a particular amount of continuous electrical power

1659200 - 3000Watts

1659201 - 4000Watts

1659202 - 6000Watts

It can supply electricity in two ways:

1. **As a back up, standby power source for a building.** For this application, you must arrange for a licensed electrician to connect the generator to your building's electrical system via the installation of an UL-approved transfer switch. The transfer switch must be installed in accordance with building electrical code and guidelines supplied by your power company.
2. **As a portable power source.** You can plug appliances or tools directly into the generator's electrical outlets.

Specific requirements for each are given below.

Note: Regardless of whether you use your generator as a back-up power source connected to a building or as a portable power source, you must not overload the generator. Overloading may cause serious damage to the generator and attached electrical devices.

Using as a Back-up Power Source for a Building

Contact a licensed electrician to install an UL-approved transfer switch if you want to use your generator as a back-up power source for a building.

What does a transfer switch do? It:

- a) Safely connects the generator to your building's electrical system by isolating your generator from your utility company's power lines, AND
- b) Connects your generator to a critical subset of your building's circuits that are needed for emergency power needs.

If your generator will be connected to your building's electrical system, it **MUST ALWAYS** be isolated from the utility power grid with a *UL-approved transfer switch installed by a licensed electrician* in compliance with all applicable building and electrical codes, and in accordance with guidelines supplied by your power company.

DANGER:

A transfer switch must be installed in order to isolate your generator from the utility power grid. If your generator is **NOT** properly isolated from the utility system, serious hazards will arise:

- ◆ When your generator is running, its output will back feed into the utility power line and transformer that are normally used to provide you with power. The transformer will step up the current to the normal line voltage. An unsuspecting utility line worker working on what he thinks is a deactivated line could be electrocuted.
- ◆ If your generator is connected (running or not) when utility power is restored, your generator will be destroyed. It could also explode or cause fire.

In addition to isolating your generator from the utility system, the transfer switch connects your generator to a limited set of circuits in your building that have been chosen as critical to operate during a power outage.

Installation / Initial Set-Up

Make sure to verify if this generator can power your loads, it may not power your entire home or farm outbuilding -- you must work with the installing electrician to determine which devices/appliances you wish to power during an outage. The electrician can help you determine which circuits and devices can be powered simultaneously without overloading the generator.

(See the previous section of this manual entitled "Power Load Planning & Management" for more information on load application and selection.)

Using as a Portable Power Source

When using the generator as a portable power source, you can plug electric devices and appliances directly into the outlets on your generator's panel.

- ◆ Make sure you plug each electrical device/appliance into the correct generator outlet based on the device's plug configuration and voltage/amperage rating. Never exceed the amperage rating of an outlet.
- ◆ Extension cords may be used to power devices that are located at a distance from the generator. However, use only UL-listed, outdoor-rated, grounded extension cords of the proper size. Additionally, if using the generator in damp or highly electrical conductive areas or on construction jobsites, always use ground fault circuit interrupter (GFCI)-equipped extension cords to prevent electrical shock. Use Table 5 below to choose an adequately sized extension cord according to the amperage of the device being used and the length of the cord.

Table 5

Current/Power		Maximum Extension Cord Length			
Amps at 240V	Load (watts)	#10 Ga. Cord	#12 Ga. Cord	#14 Ga. Cord	#16 Ga. Cord
10	2400	250'	150'	100'	75'
20	4800	125'	75'	50'	25'
30	7200	60'	35'	25'	10'
40	9600	30'	15'	10'	*
50	12000	15'	*	*	*

WARNING:

Use of under sized extension cords can cause electric shock, fire, or damage to connected devices. Failure to use GFCI extension cords in damp or wet conditions can result in severe electric shock or electrocution.

- ◆ All extension and appliance cords must be in good condition and not worn, bare, frayed, or otherwise damaged.

WARNING:

Use of damaged electric cords can cause electric shock or fire.

Note: If an extension cord becomes hot to the touch, it is overloaded or damaged and must be replaced.

Northern Tool is NOT responsible for damage or injury resulting from customer use of inadequate extension cords.

Installation / Initial Set-Up

4. Select a Suitable Site

Before using the generator, you must select a suitable **OUTDOOR** location for installation and operation of your generator. The location should meet all the criteria listed below.



WARNING:

You must choose a suitable site for operating your generator to avoid equipment damage and/or injury and possible death from carbon monoxide poisoning, electric shock, or fire. Choose a site that meets all of the criteria specified below.

Site/Location Criteria:

Dry, level surface

The generator should be positioned on a dry, firm, level surface.

Ensure that the generator sits level and will not slide or shift during operation.

Outdoors only – dangerous carbon monoxide exhaust



DANGER: Carbon monoxide poisoning hazard

The exhaust from the engine contains carbon monoxide (CO), a poisonous gas that can kill. You cannot smell it, see it, or taste it. Follow the directions below for choosing a location to operate your generator in order to avoid carbon monoxide poisoning.

The location you choose to operate the generator must be OUTDOORS and away from all air intakes:

- Never run the generator/engine assembly inside any closed or semi-enclosed spaces (even if outdoors), including homes, garages, basements, barns, sheds, or boxes. *These spaces can trap poisonous gases, even if you run a fan or open windows.*
- Place the generator so that the exhaust fumes from the engine will not be directed towards people or building air intakes.
- Ensure that working, battery-operated or battery back-up carbon monoxide alarms are used in any dwelling/structure that is in close proximity to the running generator.
- Note that this generator is NOT designed or approved for use in vehicles or marine applications. Never run the generator inside RVs or other vehicles, on boats, or on pick-up truck beds.



WARNING:

Never attempt to attach ductwork to the engine exhaust to allow for installation inside an enclosure. This could cause hot air deflection, heat build-up, and increased exhaust backpressure, resulting in possible exhaust leakage or damage to the generator or engine.

Adequate cooling ventilation

The generator needs adequate, unobstructed flow of air to allow for proper cooling of generator head.

- Situate so there is adequate clearance around generator to allow for cooling airflow so that heat does not build up. Never block vent slots. The closest object should be at 7 feet away from vents.
- Do not run the generator in close proximity to other heat-generating equipment, such as another generator. The combined heat that is generated may raise air temperature in the immediate area and there will not be adequate cooling ventilation.

Installation / Initial Set-Up

	<ul style="list-style-type: none"> • Do not allow debris to accumulate and block airflow. • Do not operate with a tarp, blanket, or cover surrounding the generator.
Hot engine exhaust clearance	<p>The exhaust gas from your engine is extremely hot and can cause combustible materials to catch on fire.</p> <ul style="list-style-type: none"> • Position engine exhaust at a safe distance from all nearby combustible materials and buildings/structures. Refer to your engine manual to determine the safe clearance distance required. • Equip the engine with a spark arrestor if the generator will be used near any ignitable forest, brush, or grassy land. Make sure you comply with applicable local, state, and federal codes. • Keep a fire extinguisher rated “ABC” nearby. Keep it properly charged and be familiar with its use.
No wet conditions	<p>Choose a location where the generator will NOT be exposed to rain, snow, or direct sunlight. Exposure to water can cause electric shock.</p> <p>You <i>may</i> operate the generator under an outdoor, canopy-like structure of heat-resistant material that is open on all sides. Make sure that all parts of canopy are:</p> <ul style="list-style-type: none"> • at least 7’ from generator • at an adequate safe clearance from hot engine exhaust. <p>Allow for adequate clearance above generator so that heat from generator does not build up.</p>
Away from dust/dirt	<p>Do not use the generator in extremely dusty or dirty conditions. Excessive dust and dirt can cause premature failure of the machine.</p>
Hearing protection	<p>Generators can produce noise levels of up to 95 dB in close proximity, which can be dangerous to human hearing with prolonged exposure. (This is in addition to the noise produced by the engine.)</p> <p>Hearing protection may be required for persons working within 15-20 feet of the running generator for an extended period of time.</p> <p>⚠ WARNING:</p> <p>Never attempt to attach ductwork to the engine exhaust to lower noise levels. This could cause hot air deflection, heat build-up, and increased exhaust backpressure, resulting in possible exhaust leakage or damage to the generator or engine.</p>


Installation / Initial Set-Up

5. Mount & Connect Generator and Engine


The recommended method to properly mount and connect the generator to the engine is to **directly mount** the generator to the engine.

Please reference the adapter plate mounting dimensions below to determine if your engine has the correct mounting pattern to allow for installation.
(see Specification page for shaft requirements)

Adapter Plate Dimensions




Item #
1659200



Item #
1659201

Installation / Initial Set-Up




Item #
1659202

Installation / Initial Set-Up

Mounting generator to engine


WARNING:

ALWAYS shut off the engine and disconnect the spark plug(s) before installation or servicing the generator. Make sure all guards and shields are replaced before using.




Step 1:

Attach the Engine Adapter plate to the mounting face of the engine using the hardware supplied with the generator head. Before tightening the bolts make sure the adapter plate is flush against the engine's machined surfaces near the mounting holes. Torque the bolts to 16 ft lbs. Misalignment will cause generator failure.



Step 2:


Carefully slide the generator head onto the shaft of the engine. Torque the bolts from the manual bag to 7.5 ft lbs. After the bolts are tight, use a wood block and "dead-blow" hammer to tap on the bearing support area of the non-drive end bracket (do not damage the capacitor with hammer). This will ensure the bearing is properly seated.



Step 3:

Use the remaining bolt & nut from the manual bag to secure the non-drive end bracket. Slide the head of the bolt into the U-shaped slot on the bottom of the non-drive end bracket. Align the bottom of the bolt with the existing isolation bracket. Tighten nut to secure the generator head.

Installation / Initial Set-Up




Step 4:

Remove spark plug(s) or spark plug wire(s) before working on the engine or generator to prevent accidental starting.

Install the Rotor Stud into the rotor through the hole in the middle of the bearing support and torque to 16 ft lbs. To keep the engine from turning have a helper pull and hold the engine's recoil start rope.

Thread the green grounding screw from the manual bag into the grounding hole on the cross bracket of the non-drive end bracket.



Step 5:


Position the end cover onto the generator by rotating the cover so that the L-shaped slots will latch onto the screw heads. Press plug (included in the manual bag) into the hole in the center of the end cover.

Installation / Initial Set-Up


6. Connecting Generator Wire Harness to Existing Wiring

Follow the detailed wiring sequence to connect the generator wire harness to your existing generator control panel.

Connect generator wire harness



To generate 240 Volts: White #2 and White #3 must be connected together.



Unit	Watts	Main Breaker Rating	Total Amps @ 120V
1659200	3000	12.5 A	25A
1659201	4000	16A	33.3A
1659202	6000	25 A	50A

⚠ WARNING: Each circuit receptacle must be protected with a breaker that is equal or less rating than the receptacle. Failure to do so could result in damage to equipment powered by the generator and the generator.

Neutral wire should be bonded to ground. Consult your local electrical code.


Installation / Initial Set-Up

7. Ground the generator

Always ensure the generator is properly grounded to prevent electrical shock.

You must always ground the generator by the following method when using the generator as a portable electrical source:

- 1) Drive a $\frac{3}{4}$ " or 1" copper pipe or rod into the ground close to the generator. The pipe/rod must penetrate moist earth – the depth required will be dictated by local soil conditions. Consult with an electrician.
- 2) Connect an approved ground clamp to the pipe.
- 3) Run a 10-gauge wire from the clamp to the generator grounding screw.
- 4) Do not connect the generator grounding post to a water pipe or a ground used by a radio system.



- 5) The generator must be grounded every time it is moved.

If a licensed electrician installs the generator with a connection to your building's electrical circuit for use as a back-up power system, grounding may alternatively be completed through the building's grounding system. Ask your electrician. If the generator is not grounded through your building's electrical system, follow the procedure above.

WARNING:



Operating the generator when it is not properly grounded can result in electrical shock.

Operation

Once you have set up your generator for use, it is time to start your generator. The following are the procedures necessary for safe, successful operation of your generator.

Operation Procedures

1. **General Safety Rules for Operation**
2. **Preparing for Operation (Pre-start checklist)**
3. **Starting the Generator**
4. **Connecting Loads**
5. **Stopping**
6. **Storage & Exercise**

Each of these procedures is discussed in detail below:

1. General safety rules for operation

Before starting the generator, review the following general safety rules for operation:



WARNING:

Failure to follow safety rules may result in serious injury or death to the operator or bystanders.




- **Know proper use/how to stop.** Be thoroughly familiar with proper use of the equipment and all generator controls, output receptacles, and connections. Know how to stop the generator quickly if needed. Refer to the engine manual for engine safety rules and operating instructions.
- **Instruct operators.** The generator owner must instruct all operators in safe generator set-up and operation. Only trained adults should set up and operate the generator – Do not let children operate.
- **Intended use.** Carefully read about and understand the intended use of this generator. Do not use for other purposes, as unforeseen hazards or equipment damage may result.
- **Under the influence.** Never operate, or let anyone else operate, the generator while under the influence of alcohol, drugs, or medication.
- **Safety guards / controls.** Do not operate the generator unless all safety covers, guards, and barriers are in place and in good working order, and all controls are properly adjusted for safe operation
- **Damaged.** Do not operate the generator with damaged, missing, or broken parts.
- **Modifications.** Do not modify the generator in any way. Modifications can create serious safety hazards and will also void the warranty.
- **Malfunction during operation.** Immediately turn off the generator if any of the following conditions arise during operation:
 - Excessive change in engine speed, slow or fast
 - Overheating in load connecting devices
 - Sparking or arcs from generator
 - Loss of electrical output
 - Receptacle damage
 - Excessive vibration
 - Flame or smoke
 - Abnormal noise
- **Adjusting / repairing.** Before working on the generator or engine, always turn off engine and remove spark plug(s) or spark plug wire(s) to prevent accidental starting. Always discharge the capacitor before working on the generator head to prevent electrical shock. (See Maintenance & Repair section of this manual for instructions on how to do this.)

Operation (cont'd)

- **Carbon monoxide poisoning.** The running engine gives off carbon monoxide, a poisonous gas that can kill you. You CANNOT smell it, see it, or taste it. Follow all instructions for site selection and positioning the generator, and avoid inhaling the exhaust. If you start to feel sick, dizzy, or weak, shut off the engine and get to fresh air RIGHT AWAY. See a doctor. You may have carbon monoxide poisoning.
- **Electrical cords.** Use only UL-listed, outdoor-rated, three prong extension cords of the proper size. All extension and appliance cords must be in good condition and not worn, bare, frayed, or otherwise damaged. Use of inadequate or damaged electric cords can cause electric shock or fire.
- **GFCI extension cords.** Always use ground fault circuit interrupter (GFCI)-equipped extension cords in damp or highly electrical conductive areas and on construction jobsites to prevent electrical shock.
- **Avoid contact.** Avoid contact with bare wires, terminals, connections, etc. while the unit is running.
- **Wet conditions.** Do not operate the generator or handle any electrical equipment while standing in water, while barefoot, while hands are wet or while in the rain or snow. Electric shock may result.
- **Electric shock accident.** If an electric shock accident occurs, immediately shut down the source of electrical power. If this is not possible, attempt to free the victim from the live conductor. Avoid direct contact with victim. Use a nonconducting implement, such as a dry rope or board, to free the victim from the live conductor. Apply first aid and get immediate medical help.
- **Smoking/sparks.** Never smoke near the running generator, and never operate near sources of sparks or flames.
- **Hot parts.** Parts of the engine and generator are extremely hot during and after operation and can burn you. Never touch hot muffler, hot exhaust manifold or any other part of the engine or generator unless you have first determined if it is hot. Wait a sufficient time for parts to cool before touching any part of the generator or engine.
- **Moving parts.** Keep hands, feet, and apparel away from drive belts, sheaves, couplings, fans, and other moving parts. Never attempt to remove any guard or shield while the unit is operating.

Operation (cont'd)

2. Preparing for Operation (Pre-start checklist)

Mount generator & engine	<p>Check that the generator and engine are mounted and connected in accordance with the instructions given earlier in this manual in the “Installation / Initial Set-up” section, “Step 5: Mount & Connect Generator to Engine”.</p> <p> WARNING: Always ensure generator and engine are properly mounted to avoid damage and injury to nearby persons, as well as development of sparks from static electricity.</p>
Position generator	<p>Check that the generator is positioned in accordance with the instructions given earlier in this manual in the “Installation / Initial Set-up” section, “Step 4: Select a Suitable Site”.</p> <p>Operate outside only, on dry, level ground with adequate clearance and ventilation.</p> <p> DANGER: Carbon monoxide poisoning hazard The engine gives off carbon monoxide exhaust, a poisonous gas that can kill. You CANNOT smell it, see it, or taste it. ONLY run generator OUTDOORS and away from air intakes. NEVER run generator inside any enclosed or semi-enclosed spaces, including homes, garages, basements, barns, sheds, boxes, pick-up truck beds, RVs, or boats. These spaces can trap poisonous gases, EVEN if you run a fan or open windows.</p>
Ground generator	<p>Make sure the generator is grounded in accordance with instructions given earlier in this manual in the “Installation / Initial Set-up” section, “Step 6: Grounding the Generator”.</p> <p> WARNING: Electric shock hazard Always ensure generator is properly grounded to prevent electrical shock.</p> <p>IMPORTANT: The generator must be grounded every time it is moved.</p>
Perform regular inspection/maintenance	<p>Make sure that any regular maintenance has been performed:</p> <ul style="list-style-type: none"> On the generator as prescribed in this manual in the “Maintenance & Repair” section; On the engine as prescribed in your engine manual, including adding/changing the oil. <p>IMPORTANT: Under long, continuous-run operating conditions, be prepared to check the engine oil level every time you refuel the engine. Remember to change the oil at the operating interval recommended in the engine owner’s manual.</p> <p>DO NOT start the generator until any needed repairs have been completed.</p>
Check/fill fuel tank	<p>Check the engine fuel level. If needed, fill tank with fresh fuel from a portable container after first reading the following instructions and warnings:</p>

Operation (cont'd)

- 1) Allow engine to cool for at least two minutes before removing gas cap.

Note: A running or still-hot engine is hot enough to ignite fuel.

- 2) When adding fuel:

- Use only a UL-approved portable fuel container to transfer fuel. Follow the safety warning and instructions below for avoiding static electric sparking.
- Do NOT overfill the fuel tank. Allow some space for fuel expansion.
- Fill fuel tank OUTDOORS – never indoors.
- Stay away from all sources of heat, sparks, and flames. Do not smoke.

- 3) Clean up fuel spills /splashes immediately.

- If possible, move the generator away from spilled fuel on the ground.
- Wipe up spilled fuel, and wait 5 minutes for excess fuel to evaporate before starting engine.
- Fuel soaked rags are flammable and should be disposed of properly.
- If fuel is spilled on your skin or clothes, change clothes and wash skin immediately.

- 4) Store extra fuel in a cool, dry place in an UL-approved, tightly sealed container.

IMPORTANT:

For continuous operation, be prepared to check and refuel the engine on a regular basis.

SPECIAL HAZARDS DURING FUELING:

WARNING: Fuel fire/explosion hazard

Gasoline is highly flammable and explosive, and standard diesel fuel is combustible. Heat, sparks, and flames can ignite fuel vapors, which can become widespread during fueling. A flash fire and/or explosion could result and cause serious injury or death. Use extreme care when handling fuel. Carefully follow all the instructions in this section to avoid the following conditions which could result in fuel vapor ignition:

- fuel vapor collection inside enclosures
- static electric sparks
- sparks from electric wiring, batteries, or running engines
- sources of heat (such as a hot engine or exhaust)
- open flames, including pilot lights

WARNING: Static electric spark hazard

A static electric spark can ignite fuel vapor, resulting in a flash fire that could cause serious injury or death.

To avoid static electric sparking while filling the fuel tank, **the following steps must be followed to minimize and safely dissipate static electric charge build-up before and during the fueling process:**


- Always dissipate static charge from your body before beginning the fueling process by touching a grounded metal object at a safe distance from fuel sources.
- Never fill the generator's fuel tank directly from the pump – the generator's tank is not grounded and high velocity flow from the pump can cause static electricity build-up. Use an approved portable container to transfer gas to the generator's tank.

Operation (cont'd)

	<ul style="list-style-type: none"> • Never fill the portable gas container while it is sitting inside a vehicle, trailer, trunk, or pick-up truck bed. ALWAYS place container on the ground to be filled. • Keep nozzle in contact with portable container while filling. Manually control the flow of fuel; do NOT use nozzle's lock-open device. • A portable container made of metal or conductive plastic is preferred because it dissipates charge to ground more readily.
Personal Protection	<ol style="list-style-type: none"> 1. Hearing can be damaged from prolonged, close-range exposure to the type of noise produced by this generator. The use of ear plugs or other hearing protection device is recommended for persons working within 15-20 feet of the running generator for an extended period of time. 2. Loose or dangling apparel and long hair can become quickly entangled in moving/rotating parts. Metal jewelry can conduct electricity. Never wear jewelry or loose-fitting clothing such as neckties, scarves, or long-sleeved or untucked shirts when starting or adjusting the generator. Tie back and secure hair close to the head.

3. Starting the Generator

After you have completed the pre-start checklist procedures, you are ready to start the generator.

Start engine	<p>Start the engine.</p> <ul style="list-style-type: none"> • Before starting, confirm there are no loads connected to the generator's outlets. • Follow the instructions provided in your engine manual for starting the engine.
Check output voltage without load	<p>Check output voltage before connecting loads to the generator.</p> <p> WARNING: The generator must be run at the correct speed in order to produce the proper electrical voltage and frequency. Failure to do so could result in damage to equipment powered by the generator and possible injury to the individual.</p> <ol style="list-style-type: none"> 1. Allow running generator to warm up for five minutes. Do not connect any loads. 2. Use portable voltage meter to check output voltage at the generator's outlets/receptacles. 3. Measured voltage should be within the following ranges: <ol style="list-style-type: none"> a. 108-132 volts at 120V receptacle(s). b. 216-264 volts at 240V receptacle(s). <p>If the output voltage is NOT within the specified range:</p> <ol style="list-style-type: none"> 1) Adjust the engine speed if possible. 2) If that doesn't work, re-verify that:

Operation (cont'd)

- | | |
|--|---|
| | <p>a) Your engine's rated horsepower meets the minimum requirement,</p> <p>3) If you are still not able to achieve acceptable output voltage, there is a problem with the engine or the generator. Refer to your engine's owner's manual for troubleshooting. If it appears that the generator itself is the problem, call NorthStar Product Support @ 1-800-270-0810 for assistance.</p> |
|--|---|

4. Connecting Loads

You will want to be careful when connecting loads so as not to overload the generator, especially if you are powering devices with motors that require a higher starting power load.

Instructions are provided below for connecting loads when you are using the generator:

- As a portable power source
- Connected to a building as a back-up power source



WARNING:

Do not overload generator. Make sure that combined starting and running loads do not exceed rated capacity of generator. Overloading the generator can cause damage to the generator and attached electrical devices, and may result in fire.

Using as a Portable Power Source

Connect electrical loads one at a time according to the following instructions:

1. Allow engine to reach operating speed by allowing it to warm up for approximately 5 minutes before connecting electrical devices.
2. After engine is warmed up, begin connecting the loads one at a time.

Start with those that require the highest wattage first. The recommended sequence is as follows:

- a. Connect items with motors such as refrigerators, freezers, air conditioners, or small hand tools, one at a time. Let each motor stabilize before connecting the next device.
 - b. Connect any lights you are planning on powering.
 - c. Connect voltage sensitive equipment such as electronics via surge protectors. Plug devices such as TV's, computers, and microwaves into a UL listed voltage surge protector, then plug the surge protector into the generator.
3. After connecting all loads, check output voltage again (for generator's first use, and periodically after that). Output voltage should remain within the following ranges:
 - a. 108-132 volts at 120V receptacle(s).
 - b. 216-264 volts at 240V receptacle(s).

If output voltage is not within the acceptable range, adjust the engine speed (if possible). If acceptable output voltage cannot be achieved no matter what the engine speed, the generator is either overloaded or there is a problem with either

Operation (cont'd)

	<p>the engine or the generator. Shut off the engine and refer to the Troubleshooting guide at the end of this manual for assistance with possible problems.</p> <p>⚠ WARNING: The generator must be run at the correct speed in order to produce the proper electrical voltage and frequency. Failure to do so could result in damage to equipment powered by the generator and possible injury to the individual.</p> <p><u>Note:</u> <i>Expect slight variations in voltage/speed with changing electrical loads.</i> <i>All engines have a tendency to slow down when a load is applied. When electrical loads are connected to the generator, the engine is more heavily loaded and as a result the speed drops slightly.</i></p> <p><i>This slight decrease in speed, together with the voltage drop within the generator itself, results in a slightly lower voltage when the generator is loaded to its full capacity than when it is running with no load. Additionally, there may be small brief surges and drops in voltage as motors connected to the generator cycle on or off.</i></p> <p><i>The slight variation in voltage has no appreciable effect in the operation of motors, lights, and most appliances, as long as output voltage remains in the acceptable range of 108-132 volts at the 120V receptacle(s) and 216-264 volts at the 240V receptacle(s).</i></p>
<p>Using as a Back-up Power Source for a Building</p>	<p>Written instructions for how to safely bring the generator online with the building's electrical system should be provided by the electrician who installs the transfer switch, and who should also provide personal instruction to the owner/operator.</p> <p>Failure to follow the proper procedure as provided by the electrician could expose persons to the hazards noted above.</p> <p><u>Note:</u> After you have brought the generator online with the transfer switch, you may need to adjust engine speed to maintain correct output voltage under load. (See more detail about maintaining proper voltage in the instructions given above for using the generator as a portable power source.)</p>

5. Stopping

Stop the generator using the following steps:

1. Disconnect all loads to generator.
(Never turn off or reduce engine speed with electrical loads connected. Damage to generator and loads will occur.)
2. Shut OFF the engine
3. Shut OFF fuel supply to the engine if possible.
4. Remove spark plug to prevent accidental starting of engine.

Operation (cont'd)

6. Storage & Exercise

When you are finished using the generator, you must:

- Make sure all loads to the generator are disconnected and fuel supply is shut off (if possible)
- Store the generator properly
- Plan on exercising the engine regularly unless the generator is prepared for long-term storage.

Detailed instructions are provided below.

Disconnect loads & shut off fuel supply

When you are finished using the generator, disconnect all loads and turn off fuel supply:

1. Make sure all devices that were connected to the generator's outlets have been disconnected.
2. Make sure fuel supply to the engine has been shut off, if possible.

Cool engine before storing

Let engine cool for at least five minutes before storing. A hot engine can be a fire hazard.

Choose a storage location

Store the generator in a location that is:

- Clean and dry
- Away from sources of heat, open flames, sparks, or pilot lights, even if the generator's fuel tank is empty. Residual fuel in the engine's tank could ignite.
- Away from extreme high or low temperatures.

Prevent accidental starting

Remove engine spark plug(s) in order to ensure the generator cannot be started accidentally in a storage location or by untrained persons.

Exercise generator every 4 weeks

The generator should be exercised regularly.

At least every four weeks, start the engine and let it run for 10 to 15 minutes with a small load plugged in, such as a lamp or fan.

Monthly exercising of the generator will:

- Dry out any moisture that has accumulated in the windings. If left, this moisture can cause corrosion in the winding.
- Ensure that the unit is operating properly should it be needed in an emergency.

Perform regular maintenance

Perform periodic maintenance as directed in this manual to keep the generator in safe working condition.

Prepare engine for long term storage if needed

If you will not be able to exercise the generator regularly, you must prepare the engine for long term storage to prevent gum deposits from forming and causing malfunction of the engine.

Operation (cont'd)

Prepare engine for long term storage by following instructions in your engine's manual or using the following procedure:

- **Removing all fuel** from the tank and carburetor
- OR
- **Adding fuel stabilizer** to the fuel (following manufacturer's instructions)

Fuel stabilizer steps:

1. Ensure fuel tank is full.
2. Add fuel stabilizer to fuel tank.
3. Run engine at least 10 minutes after adding stabilizer to allow it to enter the fuel system.
4. Shut off engine
5. Disconnect spark plug wire and remove spark plug
6. Add one teaspoon oil through spark plug hole
7. Place rag over spark plug hole and turn starter (or pull the recoil) a few times to lubricate the combustion chamber.
8. Replace spark plug, but do not reconnect the spark plug wire.

Maintenance & Repair

Inspect and maintain your generator as specified below in order to keep it in safe and optimal working order. Follow all safety rules and recommended maintenance steps.

WARNING

ALWAYS shut off the engine, disconnect the engine's spark plug(s), and discharge the capacitor before cleaning, adjusting, or servicing the generator. Make sure all guards and shields are replaced before using.

Note: The generator head is brushless and maintenance free. The bearing is a heavy-duty sealed ball bearing which requires no maintenance or lubrication.

Maintenance & Repair

Follow safety rules	<p>Read and follow these safety rules whenever you will be servicing the generator:</p> <ul style="list-style-type: none"> • Turn off generator. Always turn off generator and remove spark plug(s) or spark plug wire(s) before working on the engine or generator to prevent accidental starting. • Discharge capacitor. When the generator is shut down, the capacitor may maintain a charge. Always discharge the capacitor before working on the generator head to prevent electrical shock. Discharge using a screwdriver with an insulated handle. While wearing safety glasses, touch opposite terminals of the capacitor together with the tip of the screwdriver. If there is stored charge in the capacitor, a spark will be generated thereby discharging the capacitor. • Replace guards. Make sure all guards and shields are replaced after servicing the generator. • Repair. Major service, including the installation or replacement of parts, should be performed only by a qualified electrical service technician. Obtain factory approved parts from Northern Tool Product Support at 1-800-270-0810. • Replacement parts. If a part needs replacement, only use factory approved repair parts. Replacement parts that do not meet specifications may result in a safety hazard or poor operation of the generator and will void the warranty.
Check receptacles	<p>Check receptacles before each use to make sure they are not cracked or broken. If a receptacle is cracked or otherwise damaged, do not use until replaced with an authorized factory part. Using cracked or damaged receptacles can be both dangerous to the operator and destructive to the equipment.</p>
Keep generator clean	<p>Keep generator clean. If dust or debris accumulates on the generator, clean the generator with a damp cloth or soft bristle brush. Do not allow air intakes to become blocked.</p> <p><u>Note:</u> Do not spray generator with a garden hose or pressure washer. Water may enter the generator and cause damage to the rotor, stator, or internal windings.</p>
Check mounting	<p>Check generator mounting on a periodic basis:</p> <ol style="list-style-type: none"> 1. Make sure that the mounting bolts are tight and secure.

Maintenance & Repair (cont'd)

Perform engine maintenance	Perform engine maintenance as specified in the engine owner's manual. Engine maintenance items may include: <ol style="list-style-type: none">1. Changing oil and oil filter2. Air filter check/replacement3. Spark plug cleaning and replacement4. Spark arrestor inspection and cleaning5. Fuel filter check/replacement6. Fuel tank cleaning7. Fuel line inspection/replacement8. Battery charging/maintenance.
-----------------------------------	---

IMPORTANT:

If a part needs replacement, only use parts that meet the manufacturer's specifications. Replacement parts that do not meet specifications may result in a safety hazard or poor operation of the generator.

Contact NorthStar Product Support at 1-800-270-0810 for any questions, problems, or parts orders.

Troubleshooting

<i>TROUBLESHOOTING</i>		
<u>Problem</u>	<u>Possible Causes</u>	<u>Possible Remedies</u>
Voltage too low.	a) Engine speed too slow. b) Generator is overloaded.	a) Bring generator to a qualified technician for adjustment. b) Reduce the load. (See Power Load Planning & Mgt. Section of this manual.)
Circuit breaker trips.	a) Defective load connected to generator. b) Defective receptacle. c) Generator overloaded.	a) Disconnect load. b) Replace receptacle. c) Reduce the load. (See Power Load Planning & Mgt. Section of this manual.)
Voltage too high.	a) Engine speed too high.	a) Bring generator to a qualified technician for adjustment.
Generator overheating.	a) Generator is overloaded. b) Insufficient ventilation.	a) Reduce the load. (See Power Load Planning & Mgt. Section of this manual.) b) Make sure there is at least 7 feet of clearance on all sides of generator.
No output voltage.	a) Defective load connected to generator. b) Broken or loose wire. c) Defective receptacle. d) Defective stator. e) Defective rotor. f) Defective capacitor. g) Circuit breaker tripped.	a) Disconnect load. b) Bring generator to a qualified technician for repair. c) Replace receptacle. d) Bring generator to a qualified technician for repair. e) Bring generator to a qualified technician for repair. f) Bring generator to a qualified technician for repair. g) Reset circuit breaker and reduce loads connected to the generator.
Engine lacks power.	a) Generator is overloaded. b) Dirty air filter.	a) Reduce the load. (See Power Load Planning & Mgt. Section of this manual.) b) Clean or replace air filter.

Summary of Important Safety Information

This section provides a summary of the various safety procedures and measures that have been presented throughout the manual. Keep this summary handy and refer to it to refresh your memory about how to safely use your generator.

WARNING

Carefully read and make sure you understand the following safety information before using the generator.

Improper use or maintenance of the generator can result in *serious injury or death* from *carbon monoxide poisoning, electric shock, entanglement, fire, or burns*. In addition, the generator *can lift or flip and cause severe injury* if improperly secured.

General

- **Read manual.** Read this Owner's Manual and the engine Owner's Manual completely before attempting to set-up and use the generator. Serious injury or death can result if safety instructions are not followed.
- **Instruct operators.** The generator owner must instruct all operators in safe generator set-up and operation. Do not allow anyone to operate the generator who has not read the Owner's Manual and been instructed on its safe use.
- **Adults only.** Only trained adults should set up and operate the generator. Do not let children operate.
- **Under the influence.** Never operate, or let anyone else operate, the generator while under the influence of alcohol, drugs, or medication.
- **Intended use.** Carefully read about and understand the intended use of this generator. Do not use for other purposes, as unforeseen hazards or equipment damage may result.

Prohibition Against Modifications

- **Modifications prohibited.** Never modify or alter the generator in any way. Modifications can create serious safety hazards and will also void the warranty.
- **Fuel/exhaust system.** Never modify the engine's exhaust system, fuel tank, or fuel lines. Carbon monoxide poisoning, fire, or explosion could result.
- **Guards.** Do not operate generator unless all guards and cover shields, which prevent access to moving parts and pinch points, are in place. Failure to guard the power transmission mechanisms *may result in serious injury or death*.

Safety – Installation & Set-up

- **Mount generator and engine.** Failure to properly mount the generator may cause the unit to lift or flip during use, which could result in severe injury to the operator or bystanders, or cause damage to surrounding objects.
 - The generator and engine must be securely mounted to a common base such as a heavy-duty metal plate.
 - The mounting base must be of adequate size and strength to withstand operating torque and vibration without either flipping or experiencing stress failure.
 - See the "Installation / Initial Set-Up" section of this Owner's Manual for mounting requirements and instructions.
- **Guarding.** Clothing or hair can become rapidly entangled in unguarded rotating parts, resulting in *serious injury or death*. The customer is responsible for installing an appropriate guard if applicable.
- **Dry, level surface.** Situate generator on a dry, firm, level surface. Ensure generator sits level and will not slide or shift during operation.
- **DANGEROUS carbon monoxide exhaust - Operate OUTSIDE only!** The engine gives off carbon monoxide exhaust, a poisonous gas that can kill. You CANNOT smell it, see it, or taste it. ONLY run generator OUTDOORS and away from building air intakes. NEVER run generator inside homes, garages, barns, sheds, or other semi-enclosed spaces. These spaces can trap poisonous gases, EVEN if you run a fan or open windows.

Summary of Important Safety Information (cont'd)

- **Cooling ventilation.** The generator needs adequate, unobstructed flow of air to allow for proper cooling of engine and generator head so it does not overheat and possibly cause fire. Situate so there is adequate clearance around generator to allow for cooling airflow. Do not allow debris to accumulate and block airflow. Keep all objects at least 7 feet away from vent slots.
- **Grounding.** Always ensure generator is properly grounded to prevent electrical shock. This generator is equipped with a grounding screw. Always complete the grounding path from the generator to a copper pipe/rod driven into moist earth to a sufficient depth. Check with an electrician for local grounding requirements. If a licensed electrician installs the generator with a connection to your building's electrical circuit for use as a standby power system, grounding will be complete through the building's grounding system.
- **Isolate connection to building's electrical circuit.** Never plug the generator directly into a wall outlet. ANY connection to a building's electrical system **MUST ISOLATE THE GENERATOR FROM UTILITY POWER** via an UL-approved transfer switch installed by a licensed electrician in compliance with all applicable local building and electrical codes. If the generator is not isolated from the utility power system by such means, generator output will back feed into the utility power grid. This may result in injury or death to utility power workers or others who contact the lines during a power outage. It may also cause the generator to explode or cause fire when utility power is restored.
- **Wet conditions.** Water conducts electricity. Do not operate generator where it is wet. Operate on a dry surface under an open, canopy-like structure.
- **Hot engine exhaust.** Engine exhaust can be extremely hot and cause fire. Refer to your engine manual to determine safe clearance distance required between hot exhaust and nearby combustible objects.
- **CO alarms.** Ensure that working, battery-operated or battery back-up carbon monoxide alarms are used in any dwelling/structure that is in close proximity to the running generator.
- **Fire extinguisher.** Keep a fire extinguisher rated "ABC" by the National Fire Protection Association nearby. Keep it properly charged and be familiar with its use.

Safety – Before Use

Know how to operate

- **Review safety rules.** Before each use of this generator, review the "Rules for Safe Operation." Failure to follow these rules may result in serious injury or death.
- **Know how to operate.** Be thoroughly familiar with all controls and with the proper use of the equipment. Know how to stop the generator quickly if needed.
- **Inspect.** Before each use, inspect the generator, engine. Ensure generator/engine mounting is secure. Check for fuel leaks and loose or damaged parts. Do not operate the generator with damaged, missing, or broken parts.

Personal protective equipment

- **Hearing protection.** The use of ear plugs or other hearing protection device is recommended for those in close proximity to the generator while it is operating.
- **No loose / dangling apparel.** Loose or dangling apparel and long hair can become entangled in moving/rotating parts. Metal jewelry can conduct electricity. Never wear jewelry or loose-fitting clothing such as neckties, scarves, or long-sleeved or untucked shirts when operating the generator. Tie back hair and secure close to head.

Battery Safety

(If engine is equipped with battery start)

Batteries are hazardous because they contain caustic acid, can emit explosive gases, and can cause electric shock. *Caution must be exercised when making connections to a battery to avoid shock and contact with the acid, and to prevent any sparking that could lead to an explosion.* Follow safety rules carefully when connecting battery to engine:

- **Eye/skin protection.** Always wear eye protection and protective clothing when connecting or disconnecting battery.
- **Sparks/Smoking.** Never smoke or work near sparks or other sources of ignition.
- **Electric shock.** Never touch both battery terminals at the same time with your hand or any non-insulated tools.

Summary of Important Safety Information (cont'd)

- **Connection/disconnection sequence.** ALWAYS connect and disconnect cables to the correct battery terminals in the proper sequence:
 - When **CONNECTING** the battery, connect the **RED** cable to the **POSITIVE** terminal **FIRST**.
 - When **DISCONNECTING** the battery, disconnect the **BLACK** cable from the **NEGATIVE** terminal **FIRST**.
- **Acid/skin contact.** If battery acid contacts skin or clothing, flush immediately with water and neutralize with baking soda.

Gasoline safety - fueling your engine

Gasoline is highly flammable and explosive. You can be burned or seriously injured when handling fuel. Use extreme care when handling:

- **Fuel outdoors.** Fill fuel tank outdoors – never indoors. Gasoline vapors can ignite if they collect inside an enclosure. Explosion can result.
- **Use approved container.** Never pump fuel directly into engine at gas station. Static charge can build and ignite fuel. Use an UL approved fuel container to transfer gas to the engine.
- **Running / hot engine.** A running engine is hot enough to ignite fuel. Never add fuel or remove gas cap if engine is running or still hot. Stop the engine and allow to cool at least two minutes before adding fuel.
- **Heat / flames / sparks.** Stay away from sources of heat, flame, or sparks while adding fuel.
- **Don't overfill.** DO NOT overfill the gas tank. Allow at least 1/2" of empty space below the fill neck to allow for fuel expansion.
- **Replace cap.** Replace gas cap securely before starting engine.
- **Spills.** Clean up fuel spills immediately. Move generator away from spilled fuel on the ground. Wipe fuel off engine and wait 5 minutes for excess fuel to evaporate before starting engine. Gas soaked rags should be disposed of properly.
- **On skin / clothes.** If gasoline is spilled on your skin or clothes, change clothes and wash skin immediately.
- **Inspect fuel system.** Check fuel system on a regular basis. Look for signs of leaks, deterioration, or damaged fuel tank. Do not start engine until needed repairs have been completed.
- **Gasoline storage.** Store gasoline in a cool, dry place in an UL-approved, tightly sealed container.

Safety – During Use

- **Safety equipment / controls.** Always operate the generator with all safety covers, guards, and barriers in place and in good working order, and all controls properly adjusted for safe operation.
- **Know how to stop.** Be thoroughly familiar with proper use of the equipment and all generator controls, output receptacles, and connections. Know how to stop the generator quickly if needed.
- **Power transmission guarding.** Never operate the generator without proper guarding of the power transmission assembly, including all rotating shafts, pulleys, belts, and couplings. Clothing or hair can become rapidly entangled in unguarded rotating parts, resulting in *serious injury or death*.
- **Check output voltage.** Check output voltage to ensure the generator is working properly before connecting loads to the generator. Failure to do so could result in damage to equipment powered by the generator and possible injury to the individual. Do not adjust output speed of engine to change voltage. If voltage is not within specified range, have generator repaired by factory authorized personnel.
- **Stabilize before connecting loads.** Start generator and let engine stabilize before connecting electrical loads.
- **Do not overload.** Do not overload the generator. Make sure that combined starting and running loads do not exceed rated capacity of generator or damage will result.
- **Protect sensitive electronics.** Some electronic equipment, such as computers and audio/video equipment, can be damaged by small fluctuations in the flow of power. Use a surge suppressor for any voltage-sensitive electronic equipment you will be powering with the generator.
- **Electrical cords.** Use only UL-listed, outdoor-rated, three prong extension cords of the proper size. All extension and appliance cords must be in good condition and not worn, bare, frayed, or otherwise damaged. Use of inadequate or damaged electric cords can cause electric shock or fire.
- **GFCI extension cords.** Always use ground fault circuit interrupter (GFCI)-equipped extension cords to prevent electrical shock in damp or highly electrical conductive areas and on construction jobsites.
- **Wet conditions.** Do not operate the generator or handle any electrical equipment while standing in water, while barefoot, while hands are wet or while in the rain or snow. Electric shock may result.
- **Avoid contact.** Avoid contact with bare wires, terminals, connections, etc. while the unit is running.
- **Electric shock accident.** If an electric shock accident occurs, immediately shut down the source of electrical power. If this is not possible, attempt to free the victim from the live conductor. Avoid direct contact with

Summary of Important Safety Information (cont'd)

victim. Use a nonconducting implement, such as a dry rope or board, to free the victim from the live conductor. Apply first aid and get immediate medical help.

- **Hot parts.** Parts of the engine and generator are extremely hot during and after operation and can burn you. Never touch hot muffler, hot exhaust manifold or any other part of the engine or generator unless you have first determined if it is hot. Wait a sufficient time for parts to cool before touching any part of the generator or engine.
- **Moving parts.** Keep hands, feet, and apparel away from drive belts, sheaves, couplings, fans, and other moving parts. Never attempt to remove any guard or shield while the unit is operating.
- **Smoking/sparks.** Never smoke near the running generator, and never operate near sources of sparks or flames.
- **Carbon monoxide poisoning.** The engine gives off carbon monoxide, a poisonous gas that can kill you. You CANNOT smell it, see it, or taste it. If you start to feel sick, dizzy, or weak while using the generator, shut off the engine and get to fresh air RIGHT AWAY. See a doctor. You may have carbon monoxide poisoning.
- **Malfunction during operation.** Immediately turn off the generator if any of the following conditions arise during operation:
 - Excessive change in engine speed, slow or fast
 - Overheating in load connecting devices
 - Sparking or arcs from generator
 - Loss of electrical output
 - Receptacle damage
 - Engine misfire
 - Excessive vibration
 - Flame or smoke
 - Abnormal noise
- **Adjusting / repairing.** Before working on the generator or engine, always turn off engine and remove spark plug(s) or spark plug wire(s) to prevent accidental starting.

Safety – After use


- **Cool before storing.** Let engine and generator cool for at least five minutes before storing. Hot equipment can be a fire hazard near combustible materials.
- **Prevent accidental starting.** When generator is not in use, remove key from engine starter (key start engines) and secure in a safe location, or remove spark plug(s) or spark plug wires(s) in order to ensure that generator cannot be started in a storage location or by untrained persons.
- **Storage location.** Store the generator/engine assembly in a dry location away from sources of heat, open flames, sparks or pilot lights – such as water heaters, space heaters, furnaces, clothes dryers, or other gas appliances – EVEN IF the engine's gas tank is empty. Residual gasoline could ignite.
- **Exercise regularly.** Exercise generator every four weeks to dry out moisture that accumulates in the windings. If generator cannot be exercised on a regular basis, prepare generator for long term storage.
- **Periodic maintenance.** Perform periodic maintenance as directed in this manual to keep the generator in safe working condition.

Safety - Inspection/Maintenance


Inspect and maintain your generator on a regular basis and repair as needed to keep it in safe working condition:

- **Turn off engine.** Always turn off engine and remove spark plug(s) or spark plug wire(s) before working on the engine or generator to prevent accidental starting.
- **Discharge capacitor.** When the generator is shut down, the capacitor may maintain a charge. Always discharge the capacitor before working on the generator head to prevent electrical shock.
- **Clear debris/deposits.** Keep generator head and moving parts clean. This will ensure the generator is in safe working condition.
- **Replace guards / shields.** Make sure all guards and shields are replaced after servicing the generator.
- **Replacement parts.** If a part needs replacement, only use parts that meet the manufacturer's specifications. Replacement parts that do not meet specifications may result in a safety hazard or poor operation of the generator and will void the warranty.


Fastener Identification




M10 RIB WASHER
(QTY 4)
1659201 & 1659202
#82049




M8 RIB WASHER
(QTY 4)
1659200 ONLY
#82047




#8 X 1/2" HTEX
(QTY 1)
#82161




5/16" - 24 X 3/4" W/PATCH
(QTY 4) 1659200 ONLY
#82086



5/16" - 18x1 BOLT
(QTY 1)
#82091



3/8" - 16 X 1 W/PATCH
(QTY 4)
1659201 & 1659202
#778253



5/16" FLANGE NUT
(QTY 1)
#82019

FIG05963

Fastener Identification (cont'd)

Item # 1659200



BOLT
(QTY 4)




STAR WASHER
(QTY 4)




FLAT WASHER
(QTY 1)



NUT
(QTY 4)



Item # 1659201
&
1659202



BOLT
(QTY 4)



STAR WASHER
(QTY 4)



FLAT WASHER
(QTY 1)



NUT
(QTY 4)




1659201



1659202


FIG03135

Component List – 1659200D.1




Item #	Part #	Description	Qty
1	780422	Engine Adapter Plate	1
2	780423	Fan & bolts	1
3	31193	Drive End Bracket	1
4	780424	Enclosing Band	1
5	780425	Stator	1
6	780426	Rotor	1
7	307481	Varistor	2
8	780427	Diode	2
9	780428	Securing Stud & nut	1
10	780429	Bearing	1
11	31195	Non Drive End Bracket	1
12	780430	Capacitor	1
13	780431	Bracket Securing Stud	4
14	781874	End Cover	1
15	38271	End Cover Plug	1
16	781829	Wire Harness	1

Component List – 1659201D.1



Item #	Part #	Description	Qty
1	305522	Mount Plate (J609B)	1
2	306404	Fan Bolts	2
3	778953	Fan	1
4	306406	Drive End Bracket	1
5	778954	Enclosing Band	1
6	788184	End Cover	1
7	306408	End Cover Plug	1
8	778955	Stator	1
9	778956	Rotor	1
10	778959	Diode	2
11	778957	Securing Stud	1
12	307485	Bearing	1
14	306417	Non Drive End Bracket	1
15	778958	Capacitor	1
16	778960	Bracket Securing Stud	4
17	778961	Varistor	2
18	781829	Wire Harness	1

Component List – 1659202D.1



Item #	Part #	Description	Qty
1	779919	Mount Plate (J609B)	1
2	779556	Fan Bolts	2
3	779557	Fan	1
4	779920	Drive End Bracket	1
5	779786	Enclosing Band	1
6	788185	End Cover	1
7	38271	End Cover Plug	1
8	786125	Stator	1
9	779788	Rotor	1
10	307479	Diode	2
11	779790	Securing Stud + Nut	1
12	38276	Bearing	1
13	781829	Wire Harness	1
14	38278	Non Drive End Bracket	1
15	38279	Capacitor	1
16	779792	Bracket Securing Stud	4
17	307481	Varistor	2
18	783101	Rectifier	1

Limited Warranty

Dear Valued Customer:

The NorthStar Product you just purchased is built with the finest material and craftsmanship. Use this product properly and enjoy the benefits from its high performance. By purchasing a NorthStar product, you show a desire for quality and durability. Like all mechanical equipment this unit requires a due amount of care. Treat this unit like the high quality piece of machinery it is. Neglect and improper handling may impair its performance. Please thoroughly read the instructions and understand the operation before using your product.

Limited Warranty

NorthStar shall warranty any piece of equipment manufactured, or parts of equipment manufactured, to be free from defects in material or workmanship for a period of:

Item #	Warranty Period
1659200 1659201 1659202	90 days for residential/commercial/rental use from the date of purchase by user

NorthStar shall warranty any wear item, including, but not limited to, valves, seals, pump diaphragms, hoses, and filter elements to be free from defects in material or workmanship for a period of 90 days from the date of purchase by user. This warranty applies to the original purchaser of the equipment and is non transferable. Verification of purchase is the responsibility of the buyer. Parts will be replaced or repaired at no charge, except when the equipment has failed due to lack of proper maintenance. Any misuse, abuse, alteration or improper installation or operations will void warranty. Determining whether a part is to be replaced or repaired is the sole decision of NorthStar.

NOTE: Some services performed by parties other than NorthStar may void warranty.

This warranty covers parts only. It will not provide for replacement of complete products due to defective parts. Components not manufactured by NorthStar are guaranteed by their manufacturer and can be serviced at factory-authorized locations near you. Any costs incurred due to replacement or repair of items outside of a NorthStar approved facility is the responsibility of the buyer and not covered under warranty. NorthStar can supply you with the service center location in your area.

This warranty specifically excludes the following; failure of parts due to damage caused by accident, fire, flood, windstorm, acts of God, applications not approved by NorthStar in writing, corrosion caused by chemicals, use of replacement parts which do not conform to manufacturer's specifications, and damage caused by vandalism. Additional exclusions: loss of running time, inconvenience, loss of income, or loss of use, including any implied warranty of merchantability of fitness for a specific use.

Warranty does not cover items subject to normal wear such as tires, receptacles or any part subject to direct physical contact by the public. This warranty does not cover any personal injury or damage to surrounding property caused by failure of any part.

This warranty is in lieu of any other warranty expressed or implied and NorthStar assumes no other responsibility or liability outside that expressed within this warranty.

Please fill in the following information and have it on hand when you call in on a warranty claim.

Customer Number: _____

Date of Purchase: _____

NorthStar Serial Number: _____

Item Number: _____

This page has intentionally been left blank.



Manufactured by
Northern Tool + Equipment Co.,
2800 SouthCross Drive West
P.O. Box 1499 Burnsville, MN 55337-0499